


KASSEC Field Replacement Instructions



NOTES:

- . MTU Onsite Energy wiring is labeled according to function not wire location. Take special note that all wiring labeled six is stamped "SIX". Do not confuse these with wires stamped "9" or "6" as these are labeled nine.
- wire should be referred to MTU Onsite Energy factory service. Miswiring "9" or "6" and "SIX" wires will cause irreparable damage to the engine control. This type of damage is NOT covered under Katolight factory warranty.

For support or information, call us at 800-325-5450 or visit us at www.mtu-online.com

Materials and specifications subject to change without notice.

January 2006

MTU Onsite Energy Corporation / 100 Power Drive / Mankato, MN 56001 / USA / A Tognum Group Company